

SECTION 10522 - FIRE EXTINGUISHERS AND CABINETS

PART 1 - GENERAL

1.1 SECTION REQUIREMENTS

- A. Submittals: Product Data.

PART 2 - PRODUCTS

2.1 FIRE-PROTECTION CABINETS

- A. Fire-Protection Cabinets: Enameled-steel, semi-recessed (and surface-mounted cabinets for fire extinguisher).
 - 1. Basis-of-Design Products:
 - a. Larson, Architectural Series; Models 2409-R4 and 2409-SM
 - 2. Trim Style: Rolled trim and surface mounted.
 - 3. Door and Trim Material: Enameled steel.
 - 4. Door Glazing: Acrylic.
 - 5. Door Style: Fully glazed with frame.
 - 6. Accessories: Identification lettering and recessed handle for semi-recessed.
 - 7. Locations: Provide 2 semi-recessed cabinets with 10lb A-B-C extinguishers at locations to be determined.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install cabinets at 54 inches (1372 mm) above finished floor to top of cabinet.

END OF SECTION 10522