

## SECTION 102113 - TOILET COMPARTMENTS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

- 1. Steel toilet compartments configured as toilet enclosures, entrance screens and urinal screens.

- B. Related Sections:

- 1. Division 09 Section "Non Structural Metal Framing" for steel backing in steel stud partitions to which to anchor toilet compartment components.
  - 2. Division 10 Section "Toilet, Bath, and Laundry Accessories" for toilet tissue dispensers, grab bars, purse shelves, and similar accessories.

#### 1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes.

- B. Shop Drawings: For toilet compartments. Include plans, elevations, sections, details, and attachments to other work.

- 1. Show locations of cutouts for compartment-mounted toilet accessories.
  - 2. Show locations of reinforcements for compartment-mounted grab bars.
  - 3. Show locations of centerlines of toilet fixtures.

- C. Samples for Initial Selection: Manufacturer's color chart showing full range of colors.

- D. Samples for Verification: For the following products, in manufacturer's standard sizes unless otherwise indicated:

- 1. Each type of material, color, and finish required for units, prepared on 6-inch- (152-mm-) square Samples of same thickness and material indicated for Work.

- E. Product Certificates: For each type of toilet compartment, from manufacturer.

- F. Special Warranty: Samples of manufacturer's standard and special warranties.
- G. Maintenance Data: For toilet compartments to include in maintenance manuals.

#### 1.4 QUALITY ASSURANCE

- A. Surface-Burning Characteristics: As determined by testing identical products according to ASTM E 84, or another standard acceptable to authorities having jurisdiction, by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
  - 1. Flame-Spread Index: 25 or less.
  - 2. Smoke-Developed Index: 450 or less.
- B. Regulatory Requirements: Comply with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disabilities Act (ADA) and Architectural Barriers Act (ABA) Accessibility Guidelines for Buildings and Facilities" and ICC/ANSI A117.1 for toilet compartments designated as accessible.

#### 1.5 PROJECT CONDITIONS

- A. Field Measurements: Verify actual locations of toilet fixtures, walls, columns, ceilings, and other construction contiguous with toilet compartments by field measurements before fabrication.

### PART 2 - PRODUCTS

#### 2.1 MATERIALS

- A. Aluminum Castings: ASTM B 26/B 26M.
- B. Aluminum Extrusions: ASTM B 221 (ASTM B 221M).
- C. Brass Castings: ASTM B 584.
- D. Brass Extrusions: ASTM B 455.
- E. Steel Sheet: Commercial steel sheet for exposed applications; mill phosphatized and selected for smoothness.
  - 1. Electrolytically Zinc Coated: ASTM A 879/A 879M, 01Z (03G).
- F. Stainless-Steel Sheet: ASTM A 666, Type 304, stretcher-leveled standard of flatness.
- G. Stainless-Steel Castings: ASTM A 743/A 743M.

- H. Zamac: ASTM B 86, commercial zinc-alloy die castings.

## 2.2 STEEL UNITS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide "Academy" Series Overhead-Braced, Baked-Enamel Partitions by Sanymetal, a Crane Plumbing Co., or comparable product by one of the following:
  - 1. Accurate Partitions Corporation.
  - 2. All American Metal Corp.
  - 3. American Sanitary Partition Corporation.
  - 4. Ampco, Inc.
  - 5. Bradley Corporation; Mills Partitions.
  - 6. Flush Metal Partition Corp.
  - 7. General Partitions Mfg. Corp.
  - 8. Global Steel Products Corp.
  - 9. Hadrian Manufacturing Inc.
  - 10. Knickerbocker Partition Corporation.
  - 11. Metpar Corp.
  - 12. Rockville Partitions Incorporated.
  - 13. Shanahan's Limited.
- B. Toilet-Enclosure Style: Overhead braced, floor anchored.
- C. Entrance-Screen Style: Overhead braced, floor anchored.
- D. Urinal-Screen Style: Wall hung, flat panel, floor anchored.
- E. Door, Panel, and Pilaster Construction: Seamless, metal facing sheets pressure laminated to core material; with continuous, interlocking molding strip or lapped-and-formed edge closures; corners secured by welding or clips and exposed welds ground smooth. Provide with no-sightline system. Exposed surfaces shall be free of pitting, seam marks, roller marks, stains, discolorations, telegraphing of core material, or other imperfections.
  - 1. Core Material: Manufacturer's standard sound-deadening honeycomb of resin-impregnated kraft paper in thickness required to provide finished thickness of 1 inch (25 mm) for doors and panels and 1-1/4 inches (32 mm) for pilasters.
  - 2. Grab-Bar Reinforcement: Provide concealed internal reinforcement for grab bars mounted on units.
  - 3. Tapping Reinforcement: Provide concealed reinforcement for tapping (threading) at locations where machine screws are used for attaching items to units.
- F. Urinal-Screen Construction:
  - 1. Flat-Panel Urinal Screen: Matching panel construction.
- G. Facing Sheets and Closures: Electrolytically coated steel sheet with nominal base-metal (uncoated) thicknesses as follows:

1. Pilasters, Braced at Both Ends: Manufacturer's standard thickness, but not less than 0.0396 inch (1.01 mm).
  2. Panels: [Manufacturer's standard thickness, but not less than 0.0336 inch (0.85 mm).
  3. Doors: Manufacturer's standard thickness, but not less than 0.0336 inch (0.85 mm).
  4. Flat-Panel Urinal Screens: Thickness matching the panels.
- H. Pilaster Shoes and Sleeves (Caps): Stainless-steel sheet, not less than 0.031-inch (0.79-mm) nominal thickness and 3 inches (76 mm) high, finished to match hardware.
- I. Urinal-Screen Post: Manufacturer's standard post design of material matching the thickness and construction of pilasters with shoe and sleeve (cap) matching that on the pilaster.
- J. Brackets (Fittings):
1. Stirrup Type: Ear or U-brackets; chrome-plated zamac; stainless steel for urinal screens.
- K. Steel-Sheet Finish: Immediately after cleaning and pretreating, apply manufacturer's standard baked-on finish, including thermosetting, electrostatically applied, and powder coatings. Comply with coating manufacturer's written instructions for applying and baking. Apply one color in each room.
1. Color: As selected by Architect from manufacturer's full range.

## 2.3 ACCESSORIES

- A. Hardware and Accessories: Manufacturer's standard design, heavy-duty operating hardware and accessories.
1. Material: Chrome-plated zamac, Clear-anodized aluminum, Stainless steel, Chrome-plated brass.
  2. Hinges: Manufacturer's standard paired, self-closing type that can be adjusted to hold doors open at any angle up to 90 degrees.
  3. Latch and Keeper: Manufacturer's standard recessed latch unit designed for emergency access and with combination rubber-faced door strike and keeper. Provide units that comply with regulatory requirements for accessibility at compartments designated as accessible.
  4. Coat Hook: Manufacturer's standard combination hook and rubber-tipped bumper, sized to prevent in-swinging door from hitting compartment-mounted accessories.
  5. Door Bumper: Manufacturer's standard rubber-tipped bumper at out-swinging doors[ and entrance-screen doors].
  6. Door Pull: Manufacturer's standard unit at out-swinging doors that complies with regulatory requirements for accessibility. Provide units on both sides of doors at compartments designated as accessible.

- B. Overhead Bracing: Manufacturer's standard continuous, extruded-aluminum head rail with antigrip profile and in manufacturer's standard finish.
- C. Anchorages and Fasteners: Manufacturer's standard exposed fasteners of stainless steel or chrome-plated steel or brass, finished to match the items they are securing, with theft-resistant-type heads. Provide sex-type bolts for through-bolt applications. For concealed anchors, use stainless steel, hot-dip galvanized steel, or other rust-resistant, protective-coated steel.

## 2.4 FABRICATION

- A. Overhead-Braced Units: Provide manufacturer's standard corrosion-resistant supports, leveling mechanism, and anchors at pilasters to suit floor conditions. Provide shoes at pilasters to conceal supports and leveling mechanism.
- B. Floor-Anchored Units: Provide manufacturer's standard corrosion-resistant anchoring assemblies with leveling adjustment nuts at pilasters for structural connection to floor. Provide shoes at pilasters to conceal anchorage.
- C. Urinal-Screen Posts: Provide manufacturer's standard corrosion-resistant anchoring assemblies with leveling adjustment at tops and bottoms of posts. Provide shoes and sleeves (caps) at posts to conceal anchorage.
- D. Door Size and Swings: Unless otherwise indicated, provide 24-inch- (610-mm-) wide, in-swinging doors for standard toilet compartments and 36-inch- (914-mm-) wide, out-swinging doors with a minimum 32-inch- (813-mm-) wide, clear opening for compartments designated as accessible.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. General: Comply with manufacturer's written installation instructions. Install units rigid, straight, level, and plumb. Secure units in position with manufacturer's recommended anchoring devices.
  - 1. Maximum Clearances:
    - a. Pilasters and Panels: 1/2 inch (13 mm).
    - b. Panels and Walls: 1 inch (25 mm).
  - 2. Stirrup Brackets: Secure panels to walls and to pilasters with no fewer than two brackets attached near top and bottom of panel.
    - a. Locate wall brackets so holes for wall anchors occur in masonry or tile joints.
    - b. Align brackets at pilasters with brackets at walls.

- B. Overhead-Braced Units: Secure pilasters to floor and level, plumb, and tighten. Set pilasters with anchors penetrating not less than 1-3/4 inches (44 mm) into structural floor unless otherwise indicated in manufacturer's written instructions. Secure continuous head rail to each pilaster with no fewer than two fasteners. Hang doors to align tops of doors with tops of panels, and adjust so tops of doors are parallel with overhead brace when doors are in closed position.
- C. Floor-Anchored Units: Set pilasters with anchors penetrating not less than 2 inches (51 mm) into structural floor unless otherwise indicated in manufacturer's written instructions. Level, plumb, and tighten pilasters. Hang doors and adjust so tops of doors are level with tops of pilasters when doors are in closed position.
- D. Urinal Screens: Attach with anchoring devices to suit supporting structure. Set units level and plumb, rigid, and secured to resist lateral impact.

### 3.2 ADJUSTING

- A. Hardware Adjustment: Adjust and lubricate hardware according to hardware manufacturer's written instructions for proper operation. Set hinges on in-swinging doors to hold doors open approximately 30 degrees from closed position when unlatched. Set hinges on out-swinging doors and doors in entrance screens to return doors to fully closed position.

END OF SECTION 102113